



# County of San Diego

HERMAN REDDICK  
PROGRAM MANAGER  
(858) 974-5999  
FAX (858) 467-9662

Public Safety Group  
San Diego County Fire Authority  
5510 Overland Ave, Suite 250, San Diego, CA 92123-1239  
www.sdcountyfire.org

SUSAN QUASARANO  
PROGRAM COORDINATOR  
(858) 974-5924  
FAX (858) 467-9662

February 18, 2015

Board of Forestry and Fire Protection  
Attn: Thembu Borrás  
Room 1506-14  
1416 9th Street  
Sacramento, CA 95814

To Whom it May Concern,

On behalf of the County of San Diego, I write to submit our comments regarding the State Responsibility Area (SRA) Fire Safe Regulations, 2014.

The County of San Diego has one suggested change to the proposed regulations in the revised SRA Fire Safe Regulations in the following sections: 1270.10 Driveways, 1273.11 Gate Entrances, and 1276.04 Clearance/Treatment. We recommend that the unobstructed vertical clearance above driveways should be changed to 13' 6" to be consistent with the California Fire Code (CCR Title 24, Part 9) and other nationally-recognized standards.

Thank you for the opportunity to provide feedback, and please do not hesitate to contact me at [Herman.Reddick@sdcounty.ca.gov](mailto:Herman.Reddick@sdcounty.ca.gov) or (858) 974-5813 with any questions regarding our comments.

Sincerely,

A handwritten signature in blue ink that reads "Herman Reddick".

HERMAN REDDICK  
San Diego County Fire Authority